



## DETAIL TYPE C

## TYPICAL BELOW GROUND WALL/FLOOR DETAIL: EXISTING MASONRY WALL

NB : DO NOT SCALE - USE FIGURED DIMENSIONS ONLY.

Project: Standard Detail : Visqueen Cavity Drain Membrane System.			
RE-CD-03	Ground Bearing Raft	Cavity Drain	N/A
			Refurbishment
Visqueen Building Products Contact Technical Support : t : 0333 202 6800 f : 0333 202 6886 e : enquiries@visqueenbuilding.co.uk www.visqueenbuilding.co.uk			
COPYRIGHT RESERVED.			

**Detail Issued For Guidance Only,  
Designer's Approval Required**

Site construction sequencing should be assessed before the appropriate Visqueen Standard Detail is selected & approved by the Designer

**All cut-outs in concrete slabs to  
Structural Engineer's design**

**Visqueen Water Channel to be surrounded  
in 20mm rounded washed stone**

### WATCH POINTS :-

- 1) Ensure V20 Floor Membrane "domes" are filled as necessary to transmit floor loading.
- 2) Use mortar infill at the edge of the V20 Floor Membrane to provide a flush surface for bonding the CD 150mm Corner Strip.